

BOIL WATER NOTICE

Loss of pressure CHOCTAW LAKE WEST SIDE GEORGE'S FORK TO DAM

BOIL YOUR WATER BEFORE USING

Bring tap water to a rolling boil, boil for one minute, and cool before using. Or use bottled water certified for sale by the Ohio Department of Health. Boiled or bottled water should be used for drinking, making ice, washing dishes, brushing teeth, and preparing food until further notice.



What Happened ?

At about 8:30am on Friday, May 5th, 2018 the water system lost pressure due to a water main leak repair. When water mains lose pressure it increases the chance that untreated water and harmful microbes can enter your water.

Harmful microbes in drinking water can cause diarrhea, cramps, nausea, headaches, or other symptoms and may pose a special health risk for infants, some elderly, and people with severely compromised immune systems. But these symptoms are not just caused by microbes in drinking water. If you experience any of these symptoms and they persist, you should seek medical advice.

What is being done ? **SYSTEM IS REPAIRED – waiting on test results**

It is likely that you will need to boil water until further notice.
You will be informed when tests show that you no longer need to boil your water.

For more information, please contact:

Marti Schmidt, Choctaw Utilities Office 740-490-7184
Jim Moran, Plant Manager 740-837-0319

Please share this information with your neighbor who drink this water – we have put out notices via Email blast, Nextdoor and Fabebook in cooperation with Choctaw Property Manager